



Water and Wastewater Utility Operations, Maintenance, Engineering, Management

September 20, 2024

PRECAUTIONARY BOIL WATER NOTICE

To: City of Everglades City Water Users
PWS # 5110089

Due to repairs on a 3” water line leak located at 702 Begonia Street, a loss of water pressure was experienced to 2000 homes within the distribution system.

As a precaution until tests can be completed, we advise that all water used for drinking, cooking, making ice, washing dishes, or brushing teeth be boiled. A rolling boil of one minute is sufficient. As an alternative, BOTTLED WATER MAY BE USED.

In the event there is a loss of power, and you cannot boil water, tap water can be disinfected by adding 8 drops (or about 1/8th teaspoon) of unscented household bleach (4-6% active ingredients) to each gallon of water, then mixing the water and allowing it to stand for a minimum of 30 minutes. If the water is cloudy, use 16 drops of bleach and a 30-minute contact time.

This “Precautionary Boil Water Notice” will remain in effect until a bacterio-logical survey shows that the water is safe to drink, at which point the boil water notice will be rescinded.

If you have any questions about the testing for bacteria, please contact U.S. Water Services at (727) 848-8292. Testing normally takes 2-3 days from the time water pressure is restored or the emergency condition is corrected to complete.

4939 Cross Bayou Blvd., New Port Richey, Florida 34652

Ph: 727-848-8292 Fax: 727-849-4219 Toll Free: 866-753-8292